

10 44 13 – Fire Extinguisher Cabinets

1. General

- A. Fire extinguisher requirements (type, location, and quantity) are determined by the Fire Marshal and are governed by all applicable codes. Additional Duke Requirements for fire extinguishers may be found in **Section 10 44 16**. The Duke University Occupational and Environmental Safety Office (OESO) does not require the installation of in-wall fire extinguisher cabinets in new installations. However, if in-wall cabinets are provided, such cabinets must comply with the following requirements:
1. Fire extinguisher cabinets shall meet the ADA Standards.
 2. The minimum interior dimensions of the cabinet shall be: Height 25 inches, Width 9 1/2 inches and Depth 7 1/2 inches.
 3. Cabinets shall be flush-mounted into the wall and mounted in such a manner that the top interior height shall not exceed 5 feet as measured from the floor.
 4. Cabinets shall have flat doors with glass view plates. Bubble fronts are prohibited.
 5. Doors shall not have a key lock or other permanent type of locking device.
 6. Handles and latches are acceptable, but not necessary.