



Duke University - Facilities Management Department

Environmental Safety and Health Program

CONFINED SPACE PROGRAM

Area: All FMD Organizations

Date Effective: 16Apr10

ATMOSPHERIC TESTING (Monitor Continuously - Record test results every 30 minutes)

Location (MH#)				Periodic Re-Check						
GASES	Acceptable Conditions	Pre-Ventilation	Pre-Entry	Time:	Time:	Time:	Time:	Time:	Time:	Time:
Oxygen (O2)	19.5%to23.5%									
Flammable	<10% LEL									
Carbon Monoxide (CO)	< 35ppm									
Hydrogen Sulfide	<10ppm									
Temperature (Mh's)										
Other:										

ATMOSPHERIC TESTING (Monitor Continuously - Record test results every 30 minutes)

Location (MH#)				Periodic Re-Check						
GASES	Acceptable Conditions	Pre-Ventilation	Pre-Entry	Time:	Time:	Time:	Time:	Time:	Time:	Time:
Oxygen (O2)	19.5%to23.5%									
Flammable	<10% LEL									
Carbon Monoxide (CO)	< 35ppm									
Hydrogen Sulfide	<10ppm									
Temperature (Mh's)										
Other:										

ATMOSPHERIC TESTING (Monitor Continuously - Record test results every 30 minutes)

Location (MH#)				Periodic Re-Check						
GASES	Acceptable Conditions	Pre-Ventilation	Pre-Entry	Time:	Time:	Time:	Time:	Time:	Time:	Time:
Oxygen (O2)	19.5%to23.5%									
Flammable	<10% LEL									
Carbon Monoxide (CO)	< 35ppm									
Hydrogen Sulfide	<10ppm									

Temperature (Mh's)										
Other:										

ATMOSPHERIC TESTING (Monitor Continuously - Record test results every 30 minutes)

Location (MH#)				Periodic Re-Check						
GASES	Acceptable Conditions	Pre-Ventilation	Pre-Entry	Time:	Time:	Time:	Time:	Time:	Time:	
Oxygen (O2)	19.5%to23.5%									
Flammable	<10% LEL									
Carbon Monoxide (CO)	< 35ppm									
Hydrogen Sulfide	<10ppm									
Temperature (Mh's)										
Other:										